



0/29

7. 26/09/2024


No. F6/DFS/MS/WZ/School/2024/WZ/ 943

Dated:- 26/09/2024

FIRE SAFETY CERTIFICATE

Certified that the B.S. International School Located at Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041, comprised of Ground + 02 Upper Floors only owned/occupied by Shri Dalip Singh Educational & Welfare Society, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/WZ/778 dated 27/09/2021. The said premise was re-inspected by the officer concerned of this department on 13/09/2024 in the presence of Sh. Anoop Shokeen (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 26/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 26/09/2024 at New Delhi by


(Anul Garg)
Director
Tel No. 011-23414000
26/09/24

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, B.S. International School, Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.